

# Forward Township

Lateral Trench Inspection

Application Date: \_\_\_\_\_, 2019

This is an Application for a:

Lateral Trench Inspection (\$125.00)

Location/Address: \_\_\_\_\_  
\_\_\_\_\_

Lot #: \_\_\_\_\_

Contractor/Builder: \_\_\_\_\_

PASS  FAIL

Yes

No

Comments

|  |       |       |                          |
|--|-------|-------|--------------------------|
| Pipe SCH 40 – 4" PVC                         | _____ | _____ | Length: ____ Depth: ____ |
| Bedding Stone 1B or 2B<br>(4" min thickness) | _____ | _____ | _____                    |
| Proper Vent Installation                     | _____ | _____ | _____                    |
| Proper Trap Installation                     | _____ | _____ | _____                    |
| Proper Clean Out Installation                | _____ | _____ | _____                    |
| Minimum Slope of 1/8" / Ft.                  | _____ | _____ | _____                    |
| Proper 4" Inspection Stack                   | _____ | _____ | _____                    |
| Proper Connection to 6" WYE                  | _____ | _____ | _____                    |
| Any Additional Cleanouts                     | _____ | _____ | _____                    |

SKETCH:

Number: \_\_\_\_\_

## Office Use Only

Permit Fee Paid: \_\_\_\_\_

Sale #: \_\_\_\_\_

Check Number: \_\_\_\_\_

Inspector: \_\_\_\_\_